



- FINISH COAT
- BROWN COAT
- SCRATCH COAT
- LATH
- WRB-BOND BREAK
- WRB-DRAINAGE PLANE
- SAF (RECOMMENDED)
- FOUNDATION WEEP SCREED
- SHEATHING
- SILL SEAL

1/4" LATH GAP MIN.

NOTES

1. MINIMUM CLEARANCE = 2" OVER TREATED SLABS;
4" OVER UNTREATED SURFACES.
2. MINIMUM CLEARANCES MAY BE SET BY LOCAL
CODES. CHECK WITH THE LOCAL REQUIREMENTS.

CONCRETE STOOP

RAISED CONCRETE PAD
(BEST PRACTICE)

LEGEND

- SHEATHING, 'OSB', PLYWOOD, DENSGLOSS
- SELF ADHERED FLASHING
- PLASTER ACCESSORY
- DRAINAGE PLANE WATER RESISTANT BARRIER (WRB)
- BOND BREAK WATER RESISTANT BARRIER (WRB)
- SELF FURRING (SF) LATH
- SCRATCH COAT
- STUCCO
- SILL SEAL
- FOAM ORNAMENTALS
- GALVANIZED METAL FLASHING

TREATED

UNTREATED

FRAME COLUMN AT SLAB DETAIL



Florida Lath & Plaster Bureau (FLAPB) details are for illustration of construction methods. They are to be used as guidelines by the design and/or construction team. You should consult with your design and/or construction specialists for specific construction requirements. Some modification may be required for specific project conditions or to meet local building code. FLAPB makes no representation as to the suitability of any detail for specific use at any location on any project. A qualified, licensed architect or engineer must be consulted to specify the detail for any specific use at any location on a project.